

**Addendum No. 1**  
**BACKUP GENERATOR**  
**PUBLIC WORKS FACILITY**

Town of Goshen

September 13, 2018

This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

1. Town of Goshen Building Permit fees for this project will be waived for the Contractor. Contractor must still obtain required permit from the Building Department. Building Department office hours are Tuesday and Thursday from 7:30am to 10:00am.
2. The existing 3/8" copper gas supply line to the generator pad will be changed out by the owner to a 1/2" copper gas supply line.
3. Section 3.0 Scope of Work has been Modified from:
  - a. "The vendor will furnish and install a replacement backup generator at the Goshen Public works Facility, using the same concrete slab if possible. This generator and associated equipment will power all electrical circuits at the Public Works Facility. This is a turnkey project. It will be the responsibility of the awarded vendor to install the specified generator, wire into the existing auto transfer switch and perform any other work necessary to integrate the backup generator and auto transfer switch into the existing electrical system at the Public Works facility. The vendor will remove the existing generator and equipment from the facility."

to:

"The vendor will furnish and install a replacement backup generator at the Goshen Public works Facility, using the existing concrete slab. This generator and associated equipment will power all electrical circuits at the Public Works Facility. This is a turnkey project. It will be the responsibility of the awarded vendor to install the specified generator, wire into the existing auto transfer switch and perform any other work necessary to integrate the backup generator and auto transfer switch into the existing electrical system at the Public Works facility. Contractor shall note

that the existing auto transfer switch (Winco model # 230/150 ATS-3/B), has 3 wire start. The vendor may submit an Optional Item bid cost for replacement of the existing auto transfer switch if it will be required to operate the new generator. The vendor may submit an Optional Item bid cost for removal of the existing generator and equipment. If this item is not selected by the Town or not offered by the selected Vendor, the Town will rig and remove the existing generator unit from the concrete pad in coordination with the Contractor who will make all required disconnects of the existing generator to allow for its removal. Contractor shall coordinate this work with the Town so as not to delay the project.”

b. The specification for the automatic transfer switch has been changed from:

**Automatic Transfer Switch**

1. Not required (Existing in place inside of garage)

to:

**Optional Replacement Automatic Transfer Switch**

2. Winco 185 Series
3. 120/240 V - 125 amp
4. Nema 1 enclosure
5. Non-se rated
6. Exerciser clock
7. Time delay override

4. Section 5.0 Proposal Response Requirements has been modified to include check off Indemnification Form.
5. Section 6.0 Bid Summary has been modified to include space for an Optional Bid Item cost for the supply, installation, and removal of the existing Automatic Transfer Switch.
6. Attachments include revised:
  - Section 3.0 Scope of Work
  - Section 5.0 Proposal Response Requirements
  - Section 6.0 Bid Summary
7. Sign in Sheet from September 11, 2018 Pre-Bid Meeting

**End of Addendum No. 1**